

6 ASSEMBLY INSTRUCTIONS

6.10 Frost protection and trace heating

The system is suitable for the use of trace heating. The aluminium pipe guarantees equal heat transfer over the whole area of the pipe. The fastening of the additional heating to the pipe takes place at normal indoor temperatures using cables or self-adhesive tape. Consult Henco when use is made of self-adhesive tape for the fastening

of the trace heating to the pipe, or for better heat distribution. Trace heating must be technically approved. With the use of additional heating the temperature of the drinking water may not be higher than 60°C. It must be ensured that additional heating is switched off for water that is not circulating.

6.11 Disinfection and chlorination

The producer must be consulted beforehand in the case of the use of disinfecting products or the application

of a thermal cycle with temperatures higher than the specified temperature for use.

6.12 Earthing (conductivity)

The Henco system is not electrically conductive, and is consequently unsuitable for electrical earthing of whatever type.

